

# TODD CREEK VILLAGE METROPOLITAN DISTRICT

(Formerly Todd Creek Farms Metropolitan District No. 1)

[www.toddcreekvillage.org](http://www.toddcreekvillage.org)

## 2008 Drinking Water Consumer Confidence Report For Calendar Year 2007

Public Water System ID # CO0101157

*Esta es información importante. Si no la pueden leer, necesitan que alguien se la traduzca.*

We are pleased to present to you this year's water quality report. Our constant goal is to provide you with a safe and dependable supply of drinking water.

### General Information About Drinking Water

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA Safe Drinking Water Hotline at 1-800-426-4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides** that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and

volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

- **Radioactive contaminants**, that can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Colorado Department of Public Health and Environment prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

### Our Water Source(s)

Source	Water Type
WELL NO 2	Ground Water
WELL NO 3	Ground Water
WELL NO 4	Ground Water
WELL NO 5	Ground Water
WELL NO 6	Ground Water
WELL NO 7	Ground Water
WELL NO 8	Ground Water
WELL NO 9	Ground Water
WELL NO 10	Ground Water
WELL AL 1	Ground Water under the Influence of Surface Water
WELL AL 2	Ground Water under the Influence of Surface Water

The Colorado Department of Public Health and Environment has provided us with a Source Water Assessment Report for our water supply. You may obtain a copy of the report by visiting [www.cdphe.state.co.us/wq/sw/swaphom.html](http://www.cdphe.state.co.us/wq/sw/swaphom.html) or by contacting JIM WORLEY at 303-637-0344

Potential sources of contamination in our source water area come from:

Fallow, small grains, pasture/hay, oil/gas wells and road miles.

The Source Water Assessment Report provides a screening-level evaluation of potential contamination that **could** occur. It does not mean that the contamination **has or will** occur. We

can use this information to evaluate the need to improve our current water treatment capabilities and prepare for future contamination threats. This can help us ensure that quality finished water is delivered to your homes. In addition, the source water assessment results provide a starting point for developing a source water protection plan.

Please contact JIM WORLEY at 303-637-0344 to learn more about what you can do to help protect your drinking water sources, any questions about the Drinking Water Consumer Confidence Report, to learn more about our system, or to attend scheduled public meetings. We want you, our valued customers, to be informed about the services we provide and the quality water we deliver to you every day.

### Terms and Abbreviations

The following definitions will help you understand the terms and abbreviations used in this report:

- **Parts per million (ppm) or Milligrams per liter (mg/L)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter (µg/L)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Parts per trillion (ppt) or Nanograms per liter (nanograms/L)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
- **Parts per quadrillion (ppq) or Picograms per liter (picograms/L)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
- **Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.
- **Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

- **Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
- **Maximum Contaminant Level Goal (MCLG)** - The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL)** - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level Goal (MRDLG)**: The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Maximum Residual Disinfectant Level (MRDL)**: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Running Annual Average (RAA)**: An average of monitoring results for the previous 12 calendar months.
- **Gross Alpha, Including RA, Excluding RN & U**: This is the gross alpha particle activity compliance value. It includes radium-226, but excludes radon 222 and uranium.
- **Microscopic Particulate Analysis (MPA)**: An analysis of surface water organisms and indicators in water. This analysis can be used to determine performance of a surface water treatment plant or to determine the existence of surface water influence on a ground water well.



### Detected Contaminants

TODD CREEK VILLAGE METRO DISTRICT routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table(s) show all detections found in the period of January 1 to December 31, 2007 unless otherwise noted. The State of Colorado requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. Therefore, some of our data, though representative, may be more than one year old. The "Range" column in the table(s) below will show a single value for those contaminants that were sampled only once. Violations, if any, are reported in the next section of this report.

Note: Only detected contaminants appear in this report. If no tables appear in this section, that means that TODD CREEK VILLAGE METRO DISTRICT did not detect any contaminants in the last round of monitoring.

Organics and Inorganics	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	12/3/2007	0.023	0.02 - 0.023	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	12/3/2007	3	3	ppb	100	100	Discharge from steel and pulp mills; Erosion of natural deposits
FLUORIDE	7/11/2007	1.6	1.6	ppm	4.0	4.0	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE (AS N)	12/3/2007	0.32	0.17 - 0.32	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRATE+NITRITE (AS N)	12/3/2007	0.32	0.3 - 0.32	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
NITRITE (AS N)	7/11/2007	0.13	0.13	ppm	1	1	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Turbidity	Sample Date	Level Found	TT Requirement	Typical Source
TURBIDITY	Date: 7-23-07	Highest single measurement: .366	Maximum <u>1</u> . <u>0</u> NTU for any single measurement	Soil Runoff
	Month: 7/2007	Lowest monthly percentage of samples meeting TT requirement for our technology: 98.7%	In any month, at least 95% of samples must be less than <u>0</u> . <u>3</u> NTU	

Disinfection By-Products	Date	Average	Range	Highest RAA	Unit	MCL	MCLG	Typical Source
TOTAL TRIHALOMETHANES (TTHM)	2007	60.47	47.51 - 79.51	81	ppb	80.000	N/A	By-product of drinking water chlorination
TOTAL HALOACETIC ACIDS (HAA5)	2007	15.55	4.5 - 37.3	22	ppb	60.000	N/A	By-product of drinking water disinfection

Disinfection By-Products	Average	Range	Units	MCL	MCLG	Typical Source
CHLORITE – Distribution only	0.0	0.0	ppb	1.0	0.8	By-product of drinking water disinfection

Lead and Copper	Collection Date	90 <sup>TH</sup> Percentile	Unit	AL	Typical Source
COPPER	2005 - 2007	0.422	ppm	1.3	Corrosion of household plumbing systems; Erosion of natural deposits.
LEAD	2005 - 2007	2	ppb	15	Corrosion of household plumbing systems; Erosion of natural deposits

Radionuclides	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
GROSS ALPHA, INCLDNG RA, EXCLDNG RN & U	7/11/2007	1.3	1.3	pCi/L	15	0	Erosion of natural deposits
RADIUM, COMBINED (226, 228)	7/11/2007	0.1	0.1	pCi/L	5	0	Erosion of natural deposits

Secondary Contaminants/ Other Monitoring	Collection Date	Highest Value	Range	Unit	Secondary Standard
SODIUM	12/3/2007	220	200 - 220	MG/L	10000
SOLIDS, TOTAL DISSOLVED (TDS)	1/2/2005	1162	1162	MG/L	500

Secondary standards are non-enforceable guidelines for contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor or color) in drinking water. EPA recommends these standards but does not require water systems to comply.

### Health Information About Water Quality

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800)426-4791.

There are no additional required health effects notices.

### Violations

Violation Type	Category	Analyte	Compliance Period
MONITORING, ROUTINE (DBP), MAJOR	Failure to Monitor	CHLORITE	7/1/2007 - 7/31/2007
MONITORING, ROUTINE (DBP), MAJOR	Failure to Monitor	CHLORITE	9/1/2007 - 9/30/2007
MONITORING, ROUTINE (DBP), MAJOR	Failure to Monitor	CHLORITE	10/1/2007 - 10/31/2007
MONITORING, ROUTINE (DBP), MAJOR	Failure to Monitor	CHLORITE	11/1/2007 - 11/30/2007

### Information About the Above Violation(s)

There are no additional required health effects violation notices.

TODD CREEK VILLAGE METRO DISTRICT is required to include an explanation of the violation(s) in the above table and the steps taken to resolve the violation(s):

**In May of 2007, the District completed its conversion of the Reverse Osmosis (RO) Water Treatment Facility from treating deep well water to treating alluvial surface water. The alluvial water begins as a higher quality water source compared to the deep well water. Because the alluvial water is classified as "surface" water, state and federal water monitoring requirements increased significantly. Part of the increased monitoring included quarterly reports for chlorites. The District erred in assuming that the quarterly reports required one quarterly sample collected within the distribution system. The requirement is for monthly samples collected within the distribution system with the results forwarded to the state quarterly. When the District was notified of its error, we immediately made the change. The District has always performed daily chlorite tests at the RO plant. All samples were below or near the lowest detectable limit of .019 mg/L. The max limit is 1.0mg/L and no samples were near that level. Visit our website ([www.toddcreekvillage.org](http://www.toddcreekvillage.org)) to review water sampling results performed for 2008 through May.**